

Tony Luciano

From: Philip Partington <philip@smp-arch.com>
Sent: Tuesday, July 22, 2025 9:37 AM
To: Tony Luciano; Frank Bullock; jon.jgreenconstruction.net
Subject: Great Harvest

External (philip@smp-arch.com)

[Report This Email](#) [FAQ](#) [GoDaddy Advanced Email Security, Powered by INKY](#)

Please consider the following as ASI 11

Epoxy 2'-0" # 3 dowels 1' into existing slab at 24 O.C.

SMP ARCHITECTURE

Philip Partington AIA, NCARB
Principal
205 E Intendencia St. Pensacola, FL 32502
O: 850.739.3953 C: 850.712.5765
Philip@smp-arch.com